


Together...Shaping the Future of Electricity

EPRI's Mission

Advancing **safe, reliable, affordable** and **environmentally responsible** electricity for society through global collaboration, thought leadership and science & technology innovation

Three Key Aspects of EPRI:

Independent, Non-profit, Collaborative



The diagram consists of a central blue circle with the word "Electricity" in white. Surrounding this central circle is a larger ring divided into four colored segments: a blue segment at the top labeled "Safe", a green segment at the bottom labeled "Environmentally Responsible", a purple segment on the left labeled "Reliable", and an orange segment on the right labeled "Affordable".

© 2018 Electric Power Research Institute, Inc. All rights reserved.


EPRI electric power
research institute

Remediation Decision Making Objectives and Criteria Definitions

- Site Remediation Objective:
 - Ultimate goal of remediation project(s).
 - Dose based
 - Qualitative
 - Radionuclide concentration based
- Considerations:
 - Potential for off-site migration
 - Potential impact to plant operation
 - Potential impacts to decommissioning planning and costs
 - Potential to exceed site release criteria at license termination.
 - U.S. NRC limit: 25 mrem/yr.
 - Some states/local stakeholders may require lower dose limits.
 - Other site-specific criteria

4

© 2018 Electric Power Research Institute, Inc. All rights reserved.


 electric power
research institute

Soil and Groundwater Remediation Guidelines

Guidance Number	Guidance Statement
2.1	Define remediation objectives.
2.2	Establish site-specific investigation criteria that will be used to evaluate the outcome of initial leak or spill response.
2.3	Determine draft site release limits for soil and groundwater. These draft site release limits define the allowable concentrations in soil and groundwater that meet the NRC site release criteria at license termination.
3.1	Once initial leak or spill response is complete, survey the area to determine if residual radioactivity exists. a. If residual radioactivity is below the investigation criteria determined in Guidance Statement 2.2, further remediation evaluations are not required. b. If residual radioactivity is below the draft site release limits defined per Guidance Statement 2.3, further remediation evaluations are not required.
3.2	Characterize the extent of soil and groundwater contamination.
3.3	Evaluate the potential for contamination to migrate off-site prior to the time of decommissioning.
3.4	Estimate the extent of soil and groundwater contamination at the time of decommissioning.
3.6	Compare the radionuclide concentrations that are projected to remain in the soil and groundwater at the time of decommissioning (determined per Guidance Statement 3.4) to the draft site release limits (determined per Guidance Statement 2.2). If the projected radionuclide concentrations are below the draft site release limits defined per Guidance Statement 2.2, further remediation evaluations are not required.
3.7	Define remediation criteria.
4.1	Evaluate and select viable remediation strategies for meeting remediation objectives. Both remediation during operation and remediation during decommissioning should be considered in order to make informed decisions about when to implement remediation.
5.1	Determine the costs to implement the technically viable remediation options chosen per Guidance Statement 4.1.
6.1	Implement and monitor the selected remediation option.

6

© 2018 Electric Power Research Institute, Inc. All rights reserved.



Electric Power
Research Institute

Accessing the Guidelines

- Soil and Groundwater Remediation Guidelines: Public Edition (1023464)
<http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=0000000001023464>

7

© 2016 Electric Power Research Institute, Inc. All rights reserved.



Together...Shaping the Future of Electricity

8

© 2016 Electric Power Research Institute, Inc. All rights reserved.

